

Certificate of constancy  
of performances



Notified body 2658

**2658-CPR-5015\_FAM0196**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011  
(the Construction Products Regulation or CPR), this certificate applies to the construction product

**Data Transmission Cable U/UTP Cat 5e LSZH - Cables for general application in construction  
works subject to reaction to fire requirements (see family range in appendix)**

Placed on the market by

**Jiaxing Haitang Electronics Co., Ltd.**  
1<sup>st</sup> Jinggong Rd, Yandong Village, Wuyuan Town  
314304 Zhejiang - China

And produced in the manufacturing plant

**Jiaxing Haitang Electronics Co., Ltd.**  
1<sup>st</sup> Jinggong Rd, Yandong Village, Wuyuan Town  
314304 Zhejiang - China

This certificate attests that all provisions concerning the assessment and verification of constancy of  
performances detailed in annex ZZ of the standard

**EN 50575:2014 + A1:2016**

Under system 1+ for the performances set out here below are applied and that the factory production control  
conducted by the manufacturer is assessed to ensure the constancy of performance of the construction  
product.

**Level of class of performance: B2<sub>ca</sub>-s1a,d1,a1**

This certificate was first issued on 2019/05/22 and will remain valid as long as the test methods and/or factory  
production control requirements included harmonized standard, used to assess the performance of the  
declared essential characteristic, do not change, and the construction product, and the manufacturing  
conditions in the plant are not modified significantly, unless suspended or withdrawn by the product  
certification body.

Brussels, 2019/05/22

*P.O. Etienne Thibaut*

C. LANA

Certification Manager

**SGS**



SGS Belgium NV – Division SGS CEBEC  
Riverside Business Park  
Bld. Internationalelaan, 55 Build. D  
BE-1070 Brussels  
Tel. +32 2 556 00 20  
Fax +32 2 556 00 36

FAM0196		
Cable type	Product code	Family Name
U/UTP Cat 5e LSZH 24AWG	HT-UUTP-C5EB2	U/UTP Cat 5e LSZH

The test results are laid down in certification file ref.630309/04

This certificate is based on test reports ref. L2CPRT775 and 630309.04